



NOTES:

1. The requirement for a geotextile underlayment is based on substrate type and condition.
2. Grade of side slope should not exceed 3 to 1.
3. *The width of run-out bench shall be specified by the Project Engineer based on pull-out calculations.

Firestone 20 <i>Leading for Life</i> 09	PondGard Membrane Run-out Anchoring	Detail No. PGA-2 Systems PondGard
---	---	--